



**EASTERN IOWA COMMUNITY COLLEGES
1994 BUILDING ROOF REPLACEMENT
SCOTT COMMUNITY COLLEGE – BELMONT CAMPUS**
March 1, 2023 #23000341.00
ADDENDUM #1

A. GENERAL

1. A Pre-Bid Meeting was held on Thursday, February 23, 2023. The sign-in sheet from the meeting is attached for reference. Items discussed include the following:
 - a. Contractor will be responsible for replacing any areas of concrete sidewalk or paving damaged during construction.
 - b. Contractor will be responsible for restoring any lawn areas or landscaping damaged during construction.

B. SPECIFICATIONS

1. **SECTION 076200 – SHEET METAL FLASHING AND TRIM**
 - a. Item 2.5A Copings
The thickness noted for the copings is not correct. The new copings shall be fabricated from 24 ga. (0.0276 inch) galvanized steel and prefinished white to match the adjacent coping.

Enc.
CC: All Plan Holders



**SIGN-IN SHEET – STUDIO 483 ARCHITECTS – EICC – 1994 BUILDING ROOF REPLACEMENT
SCOTT COMMUNITY COLLEGE – BELMONT CAMPUS**

**PROJECT #19001089.00
PRE-BID MEETING – February 23, 2023**

| | NAME | COMPANY | TELEPHONE # | EMAIL ADDRESS |
|----|----------------|-----------------|--------------|---------------------------|
| 1 | Bob Braun | studio 483 | 309-786-9910 | rbraun@studio483.com |
| 2 | Joe Johnson | Economy Roofers | 503 359 6511 | Johnson.Economy@mcHSI.com |
| 3 | MIKE COTA | Jim Giese Roof | 563-285-7602 | Mcota@JimGieseRoofingCo |
| 4 | Brian VanBuren | EICC | 563-529-6354 | |
| 5 | | | | |
| 6 | | | | |
| 7 | | | | |
| 8 | | | | |
| 9 | | | | |
| 10 | | | | |
| 11 | | | | |
| 12 | | | | |
| 13 | | | | |
| 14 | | | | |
| 15 | | | | |